

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20160210-E180059  
**Report Reference** E180059-20110217  
**Issue Date** 2016-FEBRUARY-10

**Issued to:** DRAEGER SAFETY AG & CO KGAA  
REVALSTRASSE 1  
23560 LUEBECK  
GERMANY

**This is to certify that representative samples of** GAS AND VAPOR DETECTION EQUIPMENT  
CLASSIFIED FOR USE IN HAZARDOUS LOCATIONS  
See addendum page


Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** UL508 & CAN/CSA C22.2 No. 14-10, Industrial control equipment.  
UL 1203 - Explosion-Proof and Dust-Ignition-Proof Electrical Equipment for Use in Hazardous (Classified) Locations.  
UL 913 - Intrinsically Safe Apparatus and Associated Apparatus for Use in Class I, II, and III, Division 1, Hazardous (Classified) Locations

**Additional Information:** See the UL Online Certifications Directory at [www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20160210-E180059  
**Report Reference** E180059-20110217  
**Issue Date** 2016-FEBRUARY-10

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.


Class I, Groups A, B, C and D; Class II, Groups E, F and G; Class III

Explosion-proof Gas detection transmitters, Models ETR 02xx, ETR 03xx, ETR 04xx, ETR 05xx, ITR 02xx, ITR 03xx, ITR 04xx, ITR 05xx, XTR 02xx, XTR 03xx, XTR 04xx and XTR 05xx, where xx stand for different models as x0, x1, x2, xA, xB, xE and xF (instead of xx, it may also be used an asterisk \*\*).

Explosion-proof Gas detection transmitters Models ETR 02xx, ETR 03xx, ETR 04xx and 05xx provides intrinsically safe outputs for use in Class I, Groups A, B, C and D, Class II, Groups E, F, and G; Class III Hazardous Locations, when installed in accordance with Draeger control drawing number SE23161.

Explosion-proof Gas detection transmitters Models E//X followed by TR followed by 04 or 05 followed by alphanumeric characters followed by A, B, E or F provides intrinsically safe Fieldbus interface for use in Class I, Groups A, B, C and D, Class II, Groups E, F, and G; Class III Hazardous Locations installed in accordance with Draeger control drawing number SE23343.

Explosion-proof Transmitter Junction Box, Models EAC 01, followed by 0 or 1, followed by x, where x stand for different models (instead of x, it may also be used an asterisk \*) for use in Class I, Groups A, B, C, and D; Class II, Groups E, F, and G; Class III Hazardous Locations.



Bruce Mahrenholz, Director North American Certification Program  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/about/locations/>

