

TYPE APPROVAL CERTIFICATE

This is to certify:

That the Gas Detector

with type designation(s)
**IDS 01x1 and IDS 01x2 PIR 7000 (flammable hydrocarbons),
IDS 01x5 PIR 7200 (carbon dioxide)**

Issued to
**Dräger Safety AG & Co. KGaA
Lübeck, Germany**

is found to comply with
DNV GL rules for classification – Ships, offshore units, and high speed and light craft

Application :

Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV GL.

**Temperature D
Humidity B
Vibration B
EMC B
Enclosure C, D**

Issued at **Hamburg** on **2020-05-14**

for **DNV GL**

This Certificate is valid until **2025-05-13**.

DNV GL local station: **Hamburg**

Approval Engineer: **Dariusz Lesniewski**

.....
**Joannis Papanuskas
Head of Section**

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV GL AS, its parent companies and subsidiaries as well as their officers, directors and employees ("DNV GL") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to 300,000 USD.



Job Id: **262.1-031289-1**
Certificate No: **TAA00002S6**

Product description

Type: explosion proof gas transmitter with infrared sensor technology
Principle of operation: temperature-compensated infrared absorption
Gases: IDS 01x1(2): as the 'EG Type Approval Certificate BVS 08 ATEX G 001 X'
IDS 01x5: carbon dioxide
Continuous self-testing in line to IEC 61508:2010
Output signals: 4...20mA, HART (optional)
=<3,6mA (configurable) - fault, beam block warning, maintenance
Power supply: 20V DC, 3 wire (min. 13V, max. 30V)
Enclosure: Stainless Steel AISI 316 L
Connecting thread: M25 or ¾" NPT
Degree of protection: IP 66 / IP 67 / IP 68
Software version: 3.x.x

Approval conditions

The Type Approval covers hardware listed under Product description. When the hardware is used in applications to be classed by DNV GL, documentation for the actual application is to be submitted for approval by the manufacturer of the application system in each case. Reference is made to DNV GL rules for classification of ships Pt.4 Ch.9 Control and monitoring systems.

Type Approval documentation

Test Reports:	TREO No. 063-20 Issue 1, 2020-04-27 CECERT No. 416.040.2 Rev.0, 2016-06-28 CECERT No. 420.096.1 Rev.0, 2020-04-01 Dräger No. SE23356-00, 2013-07-11 Dräger No. SE20590-00, 2007-07-30
Version Report:	SE23354-2
Drawings:	SE20448-5 SE20507-5 SE20520-5 SE20525-2 SE20620-1
Instruction of use:	9023885-18
Certificates:	PTB 07 ATEX 1016, Sup. 2 DEMKO 07 ATEX 0654417 X, Sup. 4 BVS 08 ATEX G 001 X, Sup. 11
Type approval assessment report issued at Hamburg on 2019-07-09	

Tests carried out

Applicable tests according to class guideline DNVGL-CG-0339, December 2019.

Marking of product

The products to be marked with:

- manufacturer name
- model name
- serial number
- power supply ratings

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the type are complied with, and that no alterations are made to the product design or choice of systems, software versions, components and/or materials.

The main elements of the assessment are:

- Ensure that type approved documentation is available
- Inspection of factory samples, selected at random from the production line (where practicable)

Job Id: **262.1-031289-1**
Certificate No: **TAA00002S6**

- Review of production and inspection routines, including test records from product sample tests and control routines
- Ensuring that systems, software versions, components and/or materials used comply with type approved documents and/or referenced system, software, component and material specifications
- Review of possible changes in design of systems, software versions, components, materials and/or performance, and make sure that such changes do not affect the type approval given
- Ensuring traceability between manufacturer's product type marking and the type approval certificate

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE